



Product Service

CERTIFICATE

No. B 078782

Holder of Certificate: Fellowes Holdings B.V.
Gesworenhoeckseweg 3a Tilburg
The Netherlands

Certification Mark:



Product: Multiple Socket Outlets

Model(s): 685003, 685004, 685005, 685006

Model	Number of schuko socket outlets
685003	3
685004	4
685005	5
685006	6

Parameters:
Rated voltage: 250V~
Rated current: 16A
Protection class: I
Degree of protection: IP20

Tested according to: DIN VDE 0620-1:2016/A1:2017
DIN VDE 0620-2-1:2016/A1:2017
DIN VDE 0620-2-1:2021 Abschnitt 10.5

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704102404909-00
Valid until: 2026-01-01

Date, [#ISU_DT#]

(Jie Zhu)

Draft From CBW 2.0 - Production System (Build 20240717.1)